

water safety ①


कार्यालय नगर पालिक निगम. जबलपुर(म.प्र.)

क्रमांक...सहायक यंत्री/जल/158

दिनांक...13/9/24

प्रमाण पत्र


प्रमाणित किया जाता है कि सेन्ट अलायस स्कूल, गौरैयाघाट, गौर ब्रिज के पास मंडला रोड जबलपुर में नगर निगम की पाईप लाईन नहीं है, शाला में स्वयं का नलकूप स्थापित है। स्कूल में छात्र/छात्राओं/शिक्षक-शिक्षिकाओं तथा अभिभावकों हेतु स्वच्छ पेयजल की पर्याप्त व्यवस्था है।



प्र. सहायक यंत्री
जल प्रदाय विभाग
नगर निगम, जबलपुर



MANAGER
ST. ALOYSIUS SCHOOL
Gaur S.A.I.T. Campus, Mandla Road,
Near Gaur Bridge, Jabalpur (M.P.)



PRINCIPAL
ST. ALOYSIUS SCHOOL
Gaur S.A.I.T. Campus, Mandla Road,
Near Gaur Bridge, Jabalpur (M.P.)

DISTRICT WATER TESTING LABORATORY
Office of the Executive Engineer, Public Health Engg. Division Jabalpur M.P.
WATER TESTING REPORT

Report No. 97	Date 23/9/2026	UID No. JBP/
Ref. NO. 52/9-26	Date 21/9/2026	Village & Location
To, Principal ST. Aloysius School Gawn S.A.T T. Campus, mandla Road, Jabalpur.		1- ST. Aloysius School Gawn S.A.T Campus, mandla Road, Near Gawn Bridge, Jabalpur (m.p.)
Sample Collected by Atul Patel		2- 3-
Date of collection 21/9/2026		
Source Water Cooler		
Date of receipt 21/9/2026		
Date of Testing 22/9/2026		
Test conducted by Kavita, Vithika, Archana		

As per BIS 10500:2012 Reaffirmed in feb 2021 For Drinking Water

Sl no.	Characteristic	Unit	Acceptable	Cause for rejection	TEST RESULT	
					1	2

PHYSICAL-TEST

1	Turbidity	NTU	1.0	5.0	3.5	
2	Colour	Pt. Cobalt	1.0	25.0	20	
3	Taste & Odour	Agreeable	Agreeable	Agreeable	Agreeable	

CHEMICAL-TEST

4	pH	...	6.5 to 8.5	6.5 to 8.5	7.6	
5	Conductivity	M. Mohs/cm	..	..	798	
6	Alkalinity	mg/l	200	600	420	
7	Chloride (As cl)	mg/l	250	1000	110	
8	Nitrates	mg/l	45	45	5.0	
9	Total Hardness (As CaCO ₃)	mg/l	200	600	470	
10	Calcium (As Ca)	mg/l	75	200	92	
11	Magnesium (As Mg)	mg/l	30	100	58.44	
12	Total dissolved solid	mg/l	500	2000	517	
13	Iron (As Fe)	mg/l	1.00	1.0	0.3	
14	Manganese (As Mn)	mg/l	0.10	0.30	0.0	
15	Fluoride (As F)	mg/l	1.00	1.50	0.12	
16	Sulphates As So ₄	mg/l	200	400	1.10	
17	Residual Chlorine	mg/l	0.20	1.0	-	

BACTERIOLOGICAL-TEST

18	Total Coliform	per 100ml	0	..	0	
19	E Coli or Thermo tolerant coliforms	per 100ml	0	..	0	

Remark:-

Note:- 1. As above result compared with BIS 10500:2012

2. Samples are not collected by us.

3. Not to be produced at court of law.

4. We do not take any responsibility for deviation in test result due to wrong collection of sample

Kavita Rajak
21/09/2026
Chemist
Dist. Lab. Jabalpur

Office of The Municipal Corporation Jabalpur

No./H.O./2025/ 14

Date:- 4-4-25

Sanitary Certificate

It is certified that an inspection team headed by shri Santosh gour, Chief Sanitary Inspector from municipal corporation jabalpur Inspected the "St. Aloysius School" ,Gaur, S.A.I.T Campus Mandla Road Near Gaur Bridge, Jabalpur (M.P.) ,PIN CODE- 482020 , on 04-04-2025 and found that the "St. Aloysius School" ,JABALPUR has safe drinking water facilities for the student and members of staff of the School and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the state government.

The above certificate is valid for a period of 04-04-2025 to 03-04-2026


HEALTH OFFICER
Nagar Nigam Jabalpur
स्वास्थ्य अधिकारी
नगर निगम, जबलपुर



St. Aloysius School

Gaur, S.A.I.T. Campus Mandla Road,
Near Gaur Bridge, Jabalpur (M.P.)
Pin : 482020

Phone : 0761-2972662 (O), 09179427662 (M)
Visit at : www.staloyusgaur.edu.in
E-Mail : principalstaloyusgaur@gmail.com

Affiliated with Central Board of Secondary Education, New Delhi : Affiliation No. 1031294

Ref. No.

Ref. : SASG/F-26

Date -13/03/2026

To,



The Incharge
Water & Health Department
Nagar Nigam
Jabalpur

Subject : Regarding issue of Safe Drinking Water and Sanitary Condition Certificate.

Dear Sir/Madam,


With reference to the subject and as per the requirement of CBSE (Affiliation), Delhi for the fresh/renew affiliation, being the competent authority, we request you to kindly issue a Safe Drinking Water and Sanitary Condition certificate as per the enclosed proforma.

We also thank you very much for providing the certificate earlier.

You are requested to kindly issue the same at the earliest.

Thanking you in anticipation.

Yours sincerely,


Fr. S. Arockiya Raja

PRINCIPAL
ST. ALOYSIUS SCHOOL
Gaur S.A.I.T. Campus, Mandla Road,
Near Gaur Bridge, Jabalpur (M.P.)

Encl. : Certificate issued earlier